













RTU PURCHASE CONTACT INFORMATION
EMERSON POWER AND WATER SOLUTIONS WATER AUTOMATION
200 BETA DRIVE PITTSBURGH, PA. 15238 (877)826-8514
JEFF BOSSHART 205-422-3332
REF # CITY OF SAVANNAH MODEL: SVH2013

NOTES:

1. ALL ENCLOSURE WIRE TO BE #18 AWG, COLOR BLUE, TYPE 1007
2. ALL FIELD WIRING SHALL BE DONE BY OTHERS
3. * INCLUDED AT CITY DISCRETION
4. THIS DOCUMENT SUPERSEDES ANY DOCUMENTS INCLUDED WITH RTU PANEL
5. DO #8 REPLACES GENERATOR EXERCISE CLOCK
6. AI MULTI INPUT 7 CAN BE FOR ANY OF THE FOLLOWING
   FORCE MAIN PRESSURE
   FLOW METER

LIFT STATION-SCADA RTU CONTROLWAVE LOOP WIRING (VFD)

STANDARD CONSTRUCTION DETAILS

CITY OF Savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.
DATED: SEP 2013
PLATE NUMBER: S22