



EXAMPLE

ONLY

SUBMIT


FOR

PERMITTING

ASPHALT SHINGLES
15/32" SHEATHING WITH
8D NAILS AT 6" O.C.

15 lb. FELT PAPER

HURRICANE CLIPS AT EACH RAFTER
ON OUTSIDE OF WALL



METAL EAVE DRIP

1X8 FASCIA

1/2" PLYWOOD SOFFIT

2" CONTINUOUS ALUMINUM VENT

15/32" SHEATHING WITH 8D
NAILS AT 3" O.C. AT EDGES
& 12" O.C. IN FIELD

WOOD SIDING

5/8" ANCHOR BOLTS WITH 3x3x3
GAGE WASHERS AT 16" O.C. WITH 7"
MIN. EMBED. ALSO PROVIDE ANCHOR
6" TO 12" FROM END OF EACH PLATE

2X4 P.T. SOLE PLATE IF
LESS THEN 18" FROM GRADE

APPROXIMATE GRADE

2x6 RAFTERS AT 16" O.C.
WITH 1x8 RIDGE BOARD

2x6 CEILING JOISTS AT 16" O.C.

R30 INSULATION

1/2" GYP. BOARD

R13 INSULATION

SIMPSON HDU4 HOLD DOWN
ANCHOR AT ENDS OF EACH
SHEAR WALL SECTION

4" CONC. SLAB ON GRADE
W/ 6X6X10 WWM OVER TREATED
AND COMPACTED FILL

TREATED AND COMPACTED FILL

TYPICAL WALL SECTION
SCALE 1"=1'-0"

12" MINIMUM

20" MIN.

12" MIN.

(2) #5 CONT.

