



DUCITILE IRON LINE

PIPE DIA.	L
4	28
6	40
8	52
10	62
12	73
16	94
20	114
24	132

PVC LINE

PIPE DIA.	L
4	52
6	74
8	96
10	115
12	136

NOTES:

1. LENGTH OF RESTRAINT SHOWN IS IN FEET.
2. WHERE LINES CONSIST OF BOTH DUCTILE IRON AND PVC WITHIN THE LIMITS OF REQUIRED RESTRAINT, LIMITS FOR PVC SHALL APPLY.
3. FOR LINE STUBS (SEE DETAIL W39), THE LENGTH OF RESTRAINT (L) SHALL BE FROM THE VALVE AND NOT THE CAP.
4. ALL PIPES USED FOR RECLAIMED WATER SHALL BE COLOR PURPLE

STANDARD CONSTRUCTION
DETAILS



RECLAIMED WATER DEAD END RESTRAINT

PLATE NUMBER:

R17

APPROVED:

SIGNATURE ON FILE

CITY ENGINEER

SCALE: N.T.S.

DATE: DECEMBER 2005