


**NOTES:**

1. TAPPING SADDLE TO BE DUCTILE IRON WITH TYPE 304 STAINLESS STEEL FORGED DOUBLE STRAPS, STAINLESS STEEL BOLTS, NUTS, AND WASHERS. FINISH IS FUSION BONDED EPOXY TO AVERAGE THICKNESS OF 12-MILS.
2. ONE INCH (1") TAPS ON WATER LINES SMALLER THAN SIX INCHES (6") REQUIRE A TAPPING SADDLE. TWO INCH (2") TAPS REQUIRE A TAPPING SADDLE, REGARDLESS OF WATER MAIN SIZE.
3. A VALVE BOX SHALL BE USED FOR 2" CORPORATION STOPS. INSTALL PER DETAIL W4.

**1" & 2" WATER TAPPING SADDLE**

STANDARD  
CONSTRUCTION  
DETAILS



CITY OF  
*savannah*  
WATER RESOURCES AND PUBLIC WORKS BUREAU  
Planning & Engineering

SCALE: N.T.S.

DATED: JAN 2017

PLATE NUMBER:

**W3**