


NOTES:

1. THIS DETAIL APPLIES TO 2" VALVES IN WATER MAINS AND LATERALS.
2. IN UNPAVED AREAS, PROPERLY BED AND SET EDGE OF PRECAST CONCRETE COLLAR FLUSH WITH FINISHED GRADE. NO COLLAR REQUIRED IN PAVED AREAS, SET VALVE BOX FLUSH WITH PAVEMENT.
3. VALVE BOX SHALL NOT REST ON THE VALVE OR ON THE LINE.
4. CONNECT THE TRACER WIRE ON THE VALVE TO THE TRACER WIRE ON THE LINE WITH SPLICE CONNECTOR.

2" WATER VALVE AND VALVE BOX

STANDARD  
CONSTRUCTION  
DETAILS



CITY OF  
*savannah*

WATER RESOURCES AND PUBLIC WORKS BUREAU  
Planning & Engineering

SCALE: N.T.S.

DATED: JAN 2017

PLATE NUMBER:

W4