



NOTES:

1. THERE SHALL BE NO SHUTOFF VALVE IN THE FIRE DEPT. CONNECTION PIPING (PER NFPA 13).
2. ALL ABOVE GROUND FITTINGS SHALL BE FLANGED.
3. ALL PIPING SHALL BE STEEL OR DUCTILE IRON.
4. SEE SITE PLANS FOR SIZES OF PIPES AND FITTINGS. SIAMESE CONNECTION TO BE IN ACCORDANCE WITH NFPA 13.
5. PROVIDE DRAINAGE AWAY FROM STRUCTURE.
6. KNOX LOCKING PLUG SHALL BE PROVIDED ON THE FDC INLET.
7. APPROVED WAFER CHECK OR SWING CHECK VALVE WITH HORIZONTAL MOUNTED BALL DRIP VALVE.
8. THE FDC SHALL BE CONNECTED TO THE PIPING SYSTEM LOCATED DOWNSTREAM OF THE POST INDICATOR VALVE.

FREE STANDING FIRE DEPARTMENT CONNECTION

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.

DATED: JAN 2017

PLATE NUMBER:

W13