



NOTES:

1. VALVES 4" AND LARGER SHALL BE INSTALLED IN A MANHOLE.
2. VALVES SMALLER THAN 4" SHALL BE INSTALLED IN A VALVE BOX. SEE DETAIL W4.
3. ALL JOINTS SHALL BE RESTRAINED (MEGALUG OR EQUIVALENT).
4. SEE DETAIL W32 FOR RESTRAINT REQUIREMENTS UPSTREAM OF THE VALVE.

TYPICAL LINE STUB

STANDARD
CONSTRUCTION
DETAILS



CITY OF
savannah
WATER RESOURCES AND PUBLIC WORKS BUREAU
Planning & Engineering

SCALE: N.T.S.
DATED: JAN 2017
PLATE NUMBER:
W34